



Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Hiandri Limited
152 Oxford Terrace
Christchurch, 8011
New Zealand

Test standard: AS 1530.4:2014

Specimen name: GIB® Fire Rated Timber Framed Wall Systems with Hiandri packer system

Specimen description: Winstone Wallboards Limited fire rated timber wall systems with the Hiandri packer system consisting of a Hiandri packer, polyurethane expanding foam and GIB Fire Soundseal® installed with the following GIB® systems:

GIB® systems	FRR
GBUW 15	15/15/15
GBTL30, GBTL 30b, GBTL 30c, GBUW 30a, GBUW 30b, GBTLA 30a, GBTLA 30b, GWTLE 30 or GWTLP 30	30/30/30
GBTLA 45r and GBTLIC 45	45/45/45
GBTL 60, GBTL 60b, GBUW 60, GBTLAB 60a, GBTLAB 60b, GBTLAB 60c, GBTLAB 60d, GBTLA 60, GBTLA 60r, GBTLIC 60, GBTLIC 60a, GWTLE 60a, GWTLE 60b or GWTLP 60	60/60/60
GBTL 90*, GBUW 90, GBTLA 90c or GBTLA 90d or GBTLA 90r	90/90/90
GBT 120a or GBT 120b*	-/120/120
GBTL 120 or GBUW 120	120/120/120

* These systems require a 9 mm thick plywood packer inline with each stud.

Orientation: Two way walls - Exposure from either face.
One way walls (universal walls) – Exposure from the plasterboard face only

A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:

BRANZ Fire Assessment Report FC17909-01-1

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports before approving any product.

Certificate issued: 9 September 2026

Certificate Number: FC11824-02-C1-2

P. Chapman
Senior Fire Testing Engineer
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."